

# Energy performance certificate (EPC)

Honey Corse Laugharne CARMARTHEN SA33 4RP	Energy rating <b>E</b>	Valid until: <b>21 May 2028</b>
		Certificate number: <b>8401-7135-9829-7197-7583</b>

## Property type

Detached house

## Total floor area

252 square metres

## Rules on letting this property


Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions \(https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance\)](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance).

## Energy efficiency rating for this property

This property's current energy rating is E. It has the potential to be B.

[See how to improve this property's energy performance.](#)



The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

### Breakdown of property's energy performance

This section shows the energy performance for features of this property. The assessment does not consider the condition of a feature and how well it is working.

Each feature is assessed as one of the following:

- very good (most efficient)
- good
- average
- poor
- very poor (least efficient)

When the description says "assumed", it means that the feature could not be inspected and an assumption has been made based on the property's age and type.

Feature	Description	Rating
Wall	Granite or whinstone, as built, no insulation (assumed)	Very poor
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, no insulation	Very poor

Feature	Description	Rating
Roof	Flat, insulated (assumed)	Good
Window	Fully double glazed	Good
Main heating	Boiler and radiators, oil	Average
Main heating control	Programmer, TRVs and bypass	Average
Hot water	From main system	Average
Lighting	Low energy lighting in all fixed outlets	Very good
Floor	Solid, no insulation (assumed)	N/A
Floor	Solid, insulated (assumed)	N/A
Secondary heating	None	N/A

## Primary energy use

The primary energy use for this property per year is 229 kilowatt hours per square metre (kWh/m<sup>2</sup>).

► [What is primary energy use?](#)

## Additional information

Additional information about this property:

- Stone walls present, not insulated
- Dwelling may be exposed to wind-driven rain

## Environmental impact of this property

This property's current environmental impact rating is F. It has the potential to be C.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO<sub>2</sub>) they produce each year. CO<sub>2</sub> harms the environment.

## An average household produces

6 tonnes of CO<sub>2</sub>

## This property produces

15.0 tonnes of CO<sub>2</sub>

## This property's potential production

4.6 tonnes of CO<sub>2</sub>

You could improve this property's CO<sub>2</sub> emissions by making the suggested changes. This will help to protect the environment.

Environmental impact ratings are based on assumptions about average occupancy and energy use. They may not reflect how energy is consumed by the people living at the property.

Improve this property's energy rating

► [Do I need to follow these steps in order?](#)

---

## Step 1: Increase loft insulation to 270 mm

Typical installation cost

£100 - £350

Typical yearly saving

£323

Potential rating after completing step 1

53 | E

---

## Step 2: Internal or external wall insulation

Typical installation cost

£4,000 - £14,000

Typical yearly saving

£392

Potential rating after completing steps 1 and 2

65 | D

---

## Step 3: Floor insulation (solid floor)

Typical installation cost

£4,000 - £6,000

Typical yearly saving

£36

Potential rating after completing steps 1 to 3

66 | D

---

## Step 4: Heating controls (room thermostat)

Typical installation cost

£350 - £450

---

Typical yearly saving

£72

---

Potential rating after completing steps 1 to 4

68 | D

---

## Step 5: Replace boiler with new condensing boiler

Typical installation cost

£2,200 - £3,000

---

Typical yearly saving

£116

---

Potential rating after completing steps 1 to 5

71 | C

---

## Step 6: Solar water heating

Typical installation cost

£4,000 - £6,000

---

Typical yearly saving

£31

---

Potential rating after completing steps 1 to 6

72 | C

---

## Step 7: Solar photovoltaic panels, 2.5 kWp

Typical installation cost

£5,000 - £8,000

---

## Typical yearly saving

£296

---

## Potential rating after completing steps 1 to 7

77 | C

---

## Step 8: Wind turbine

### Typical installation cost

£15,000 - £25,000

---

## Typical yearly saving

£576

---

## Potential rating after completing steps 1 to 8

86 | B

---

## Paying for energy improvements

You might be able to get a grant from the [Boiler Upgrade Scheme \(https://www.gov.uk/apply-boiler-upgrade-scheme\)](https://www.gov.uk/apply-boiler-upgrade-scheme). This will help you buy a more efficient, low carbon heating system for this property.

### Estimated energy use and potential savings

Based on average energy costs when this EPC was created:

### Estimated yearly energy cost for this property

£1976

---

### Potential saving if you complete every step in order

£971

---

The estimated cost shows how much the average household would spend in this property for heating, lighting and hot water. It is not based on how energy is used by the people living at the property.

## Heating use in this property

Heating a property usually makes up the majority of energy costs.

### Estimated energy used to heat this property

Type of heating

Estimated energy used

Space heating

33441 kWh per year

Type of heating

Estimated energy used

---

Water heating

2374 kWh per year

## Potential energy savings by installing insulation

Type of insulation

Amount of energy saved

Loft insulation

6364 kWh per year

---

Solid wall insulation

7724 kWh per year

## Saving energy in this property

[Find ways to save energy in your home.](#)

### Contacting the assessor and accreditation scheme

This EPC was created by a qualified energy assessor.

If you are unhappy about your property's energy assessment or certificate, you can complain to the assessor directly.

If you are still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation schemes are appointed by the government to ensure that assessors are qualified to carry out EPC assessments.

## Assessor contact details

### Assessor's name

Adrian Reynolds

---

### Telephone

07717 495144

---

### Email

[m7acr@sky.com](mailto:m7acr@sky.com)

---

## Accreditation scheme contact details

### Accreditation scheme

Stroma Certification Ltd

---

### Assessor ID

STRO005302

---

### Telephone

0330 124 9660

---



## Email

[certification@stroma.com](mailto:certification@stroma.com)

---

## Assessment details

### Assessor's declaration

No related party

---

### Date of assessment

17 May 2018

---

### Date of certificate

22 May 2018

---

### Type of assessment

▶ [RdSAP](#)

---

### Other certificates for this property

If you are aware of previous certificates for this property and they are not listed here, please contact us at [dluhc.digital-services@levellingup.gov.uk](mailto:dluhc.digital-services@levellingup.gov.uk) or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

There are no related certificates for this property.