

Energy performance certificate (EPC)

Spring Rise
Stepaside
NARBERTH
SA67 8JN

Energy rating

C

Valid until:

15 July 2036

Certificate
number:

0350-2655-6660-2796-1335

Property type

Detached bungalow

Total floor area

102 square metres

Rules on letting this property

Properties can be let if they have an energy rating from A to E.

You can read [guidance for landlords on the regulations and exemptions](https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance) (<https://www.gov.uk/guidance/domestic-private-rented-property-minimum-energy-efficiency-standard-landlord-guidance>).

Energy rating and score

This property's energy rating is C. It has the potential to be C.

[See how to improve this property's energy efficiency.](#)

The graph shows this property's current and potential energy rating.

Properties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy bills are likely to be.

For properties in England and Wales:

the average energy rating is D
the average energy score is 60

Score	Energy rating	Current	Potential
92+	A		
81-91	B		
69-80	C	76 C	78 C
55-68	D		
39-54	E		
21-38	F		
1-20	G		

Breakdown of property's energy performance

Features in this property

Features get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how well features work or their condition.

Assumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

Feature	Description	Rating
Wall	Cavity wall, as built, insulated (assumed)	Good
Roof	Pitched, 200 mm loft insulation	Good
Roof	Pitched, insulated (assumed)	Average
Roof	Flat, insulated	Good
Window	Fully double glazed	Average
Main heating	Air source heat pump, radiators, electric	Good
Main heating control	Time and temperature zone control	Very good
Hot water	From main system	Average
Lighting	Good lighting efficiency	Good
Floor	Solid, no insulation (assumed)	N/A
Floor	Solid, insulated (assumed)	N/A
Air tightness	(not tested)	N/A
Secondary heating	None	N/A

Low and zero carbon energy sources

Low and zero carbon energy sources release very little or no CO₂. Installing these sources may help reduce energy bills as well as cutting carbon emissions. The following low or zero carbon energy sources are installed in this property:

- Air source heat pump
- Solar photovoltaics

Primary energy use

The primary energy use for this property per year is 67 kilowatt hours per square metre (kWh/m²).

Additional information

Additional information about this property:

- PVs or wind turbine present on the property (England, Wales or Scotland)
The assessment does not include any feed-in tariffs that may be applicable to this property.

Smart meters

This property had a **smart meter for electricity** when it was assessed.

Smart meters help you understand your energy use and how you could save money. They may help you access better energy deals.

[Find out about using your smart meter \(https://www.smartenergygb.org/using-your-smart-meter\)](https://www.smartenergygb.org/using-your-smart-meter)

How this affects your energy bills

An average household would need to spend **£1,483 per year on heating, hot water and lighting** in this property. These costs usually make up the majority of your energy bills.

You could **save £87 per year** if you complete the suggested steps for improving this property's energy rating.

This is **based on average costs in 2026** when this EPC was created. People living at the property may use different amounts of energy for heating, hot water and lighting.

Heating this property

Estimated energy needed in this property is:

- 10,251 kWh per year for heating
 - 1,909 kWh per year for hot water
-

Impact on the environment

This property's environmental impact rating is A. It has the potential to be A.

Properties get a rating from A (best) to G (worst) on how much carbon dioxide (CO₂) they produce each year.

Carbon emissions

An average household produces	6 tonnes of CO ₂
-------------------------------	-----------------------------

This property produces	0.7 tonnes of CO ₂
------------------------	-------------------------------

This property's potential production	0.6 tonnes of CO ₂
--------------------------------------	-------------------------------

You could improve this property's CO₂ emissions by making the suggested changes. This will help to protect the environment.

These ratings are based on assumptions about average occupancy and energy use. People living at the property may use different amounts of energy.

Steps you could take to save energy

Step	Typical installation cost	Typical yearly saving
1. Floor insulation (solid floor)	£5,000 - £10,000	£86

Advice on making energy saving improvements

[Get detailed recommendations and cost estimates \(www.gov.uk/improve-energy-efficiency\)](http://www.gov.uk/improve-energy-efficiency)

[Speak to an advisor from Nest \(www.gov.wales/get-help-energy-efficiency-your-home-nest\)](http://www.gov.wales/get-help-energy-efficiency-your-home-nest)

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it.

Assessor's name	Eleanor Black
Telephone	07463906747
Email	eleanormblack@hotmail.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/025214
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	15 June 2026
Date of certificate	16 July 2026
Type of assessment	RdSAP
